

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211352
Address: 4824 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Eric Sharp	Passed	Wednesday, June 29, 2022

Informational:
1 Misc 5-20-22 AN forms are in place and aggregate is present. Told concrete crew they still needed to compact the aggregate

Informational:
2 Misc 6-29-22 driveway looks good and has expansion joints at curb and right of way. Meets ADA Apec

Comments: