



**LEE'S SUMMIT**  
MISSOURI



## **FIRE DEPARTMENT**

**Prevention Division**  
**(816)969-1300**

### **PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20220884	Date:	June 29, 2022
Project Title:	ANYTIME FITNESS	Applicant:	
Location:	3508 SW MARKET ST, LEES SUMMIT, MO 640823504 SW MARKET ST, LEES SUMMIT, MO 64082		ELECTRONIC SYSTEMS INTEGRATION LLC 6516 N LONDON DR KANSAS CITY, MO 64151
Type of Work:			
Occupancy Group:	A-4	Primary:	(913) 626-0263
Description:	TENANT FINISH FOR GYM		
Construction Type:	Type VB (Unprotected)		
Map Page:			

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Alarm Plan Review**

**Reviewed By: Jim Eden**

**Released for Construction**

1. 2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. .A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Received 6/29/2022.

2. 2018 IFC 904.4.2- Alarm testing. Notification appliances, connections to fire alarm systems, and connections to approved supervising stations shall be tested in accordance with this section and Section 907 to verify proper operation.

Call (816) 969-1300 to schedule an alarm, preferably outside of other store business hours.

3. 2018 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

The existing panel shall have documentation of an annual inspection. Verified at inspection.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**