

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211697  
Address: 4737 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Adam Nacke	Passed	Wednesday, June 29, 2022

Corrective Action Required:

1	Miscellaneous Correction	6-15-22 AN sidewalk is not completed to property line there is also a valve riser in the sidewalk that will have to be lowered. Also there is a broken sidewalk panel that will need to be replaced
---	--------------------------	---

Informational:

2	Misc	6-29-22 AN sidewalk is now complete. Valve lowered and broken panel is replaced
---	------	---

**Comments:**