

DEVELOPMENT SERVICES

Residential Plan Review

June 29, 2022

NEW MARK HOMES - KC LLC 5207 NW CROOKED ROAD PARKVILLE, MO 64152 (816) 969-9010

Permit No: PRRES20222963

Plan Name:

Project Address: 2091 NW OBRIEN RD, LEES SUMMIT, MO 64081

Parcel Number: 262459

Location: WOODSIDE RIDGE 2ND PLAT LOTS 144 THRU 198 INCLUSIVE AND TRACTS I, J AND K --- LOT 174

Type of Work: NEW SINGLE FAMILY

Occupancy Group: RESIDENTIAL, ONE- AND TWO-FAMILY

Description: NEW HOUSE - UNFINISHED BASEMENT - COVERED DECK

Revisions Required

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide two (2) copies of any revised sheets and/or additional information.

Development Services Department (816) 969-1200

Plot Plan Review Reviewed By: Kim Brennan Approved

1. Basement egress location(s) and elevation of the lowest adjacent grade must be provided on the plot plan.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

| Residential Area: | | | | |
|---------------------------------------------|-------|---------------------|------|--|
| Residential, Decks | | 250 | | |
| Residential, Finished basements | | 18 | | |
| Residential, garage | | 640 | | |
| Residential, Living Area (Not Finished Base | ment) | 2592 | | |
| Residential, Un-Finished basements | | 1420 | | |
| | | | | |
| Roofing Material | | Number of Bathrooms | 3.5 | |
| Number of Bedrooms | 4 | Number of Stories | 1 | |
| Number of Living Units | 1 | Total Living Area | 2592 | |
| Sewer Connection Fee | 19 | | | |

| 220 SE Green Street Lee's Summit, MO 64063 816.969.1200 816.969.1201 Fax cityofLS.net/Development Page 2 | | | | | | |
|------------------------------------------------------------------------------------------------------------------|--|--|--|--|--|--|