

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214650
Address: 415 SW JEFFERSON ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Wednesday, June 29, 2022

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">- secure whip to water heater at the ceiling.-remove NM to basement bath vanity light.-no box was provided open wires above ceiling.-remove NM from box in storage area from switch to both ceiling lights.- provide a letter from the plumbing contractor on the under slab plumbing that was not inspected.-provide letter from GC that all portions of the construction that was not inspected was installed per code and future work covered without inspection will be uncovered or removed.-Complete corrections for Fire Department |
|---|------|---|

Comments: