


June 24, 2022

**Summit Homes** 120 SE 30th St. Lee's Summit, MO 64082

## RE: Bracing revision for Lot #116 Reserve at Stoney Creek- 1924 SW Hightown Dr, Lee's Summit, MO 64082 -Permit # PRRES20215839

Bracing Revision shall be as follows

- Block wall a 3' O.C. in bracing areas indicated in picture.
- Seheathing shall be nailed @ 12" O.C. field and 6" O.C. edge.
- Nail sheathing to blocking at 6" O.C.
- Strap blocking to adjacent studs with CS 16 strap.
- See image below



Sincerely,

Bradley Huxol, PE

