

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20221062

Address: 904 NW PRYOR RD, LEES SUMMIT, MO 64081908 NW PRYOR RD, LEES SUMMIT, MO 64081900 NW
PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Proof Roll	Eric Sharp	Passed	Thursday, June 30, 2022

Informational:

1 Misc

ESS performed a proof roll on curb sections today using a truck with 20.05 ton load. All areas passed. 6/15/22 ES

ESS performed a proof roll for base asphalt using a truck with 20.0 tons of rock. All areas passed. 6/30/22 ES

Comments: