

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201372
Address: 4701 NE FREEHOLD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Thursday, June 30, 2022

Corrective Action Required:

1	Misc	-Clean out dirt inside water meter to gravel bed -Provide sewer tracer wire port at grade -Pendant light in master bathroom cannot be within the bathtub zone -Install secondary lock for the slide door per security code -Install smoke alarm in rear basement bedroom
---	------	--

Comments: