

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211706  
Address: 2349 SW OLD PORT RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Shawn Hoffman	Failed	Thursday, June 30, 2022

Corrective Action Required:

1	Miscellaneous Correction	driveway inspection pending Pay fee's Final grading and sod Splash blocks Sump discharge minimum of 36" from foundation Missing nails in joist hangers under deck Seal all exterior penetrations Seal top of meter can and A/C disconnect Attach electrical whip at water heater Uncover smoke detectors
---	-----------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Comments:**