

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214577
Address: 3116 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Friday, July 01, 2022

Corrective Action Required:

1 Misc

- truss screws to be installed per manufacture specifications throughout
- seal gaps in fireblocking at furr down ends in basement (frame around beam and fireblock S wall)
- vertical to horizontal fire blocking every 10' (missing and penetrations)
- fire block into furr down near wall bar
- anchor bolts to be in the middle 1/3 of sill plate in basement
- top plate penetration in bath 3
- fire block dead space to ceiling space and furr down in basement bath 1
- fire block furr out wall to ceiling space in bed 4
(See furr down)
- truss hangers to plans incorrect hanger sul26

Comments: