

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216532
Address: 1812 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Not Ready	Friday, July 01, 2022

Corrective Action Required:

1	Misc	NOT READY FOR INSPECTION, MISSING FIRE BLOCKING THORUGHOUT, CHASES AND FUR DOWNS, NO FUR OUTS FOR INSULATION, SEVERAL JOIST HANGERS MISSING
		WRONG ADDRESS PLAN SET ON SITE

Comments: