CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20221062

Address: 904 NW PRYOR RD, LEES SUMMIT, MO 64081908 NW PRYOR RD, LEES SUMMIT, MO 64081900 NW

PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date: **Pavement-Surface** Eric Sharp Partial Tuesday, July 05, 2022 Informational: 1 Misc Proof roll passed and Seal-O-Matic will be looking to start paving operations on 7/1. They are still awaiting an approval on change of plan to do 1 - 4" lift of base and 1 - 2.5" lift of surface. 6/30/22 ES Informational: 2 Installing 4inches of base asphalt today. Coming back on Monday to do Misc surface Informational: Seal-o-matic on site laying top 2.5" of surface asphalt today. 7/5/22 ES Misc

Comments: