

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20216366
Address: 3635 NE AKIN DR, Unit:WTR, LEES SUMMIT, MO 640643691 NE AKIN DR, Unit:WTR, LEES SUMMIT, MO 640643695 NE AKIN DR, Unit:WTR, LEES SUMMIT, MO 640643635 NE AKIN DR, Unit:A, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Proof Roll	Adam Nacke	Partial	Tuesday, July 05, 2022

Informational:

1 Misc 6-15-22 AN type 5 base is down and they are ready for proof roll

Corrective Action Required:

2 Miscellaneous Correction 6-16-22 AN we did a proof roll with a 20 ton load and it failed . There was 3 bad spots and they will dig up and replace

Informational:

3 Misc 6-17-22 AN crew is digging out the problem area and fixing them. We still need to do a proof roll on one of the side street.

6-20-22 AN crew did proof roll on the side street and it failed . (problem areas were fixed and are good now) pics attached

7-5-22 AN concrete crew is doing the first pour of the road and we did not need a proof roll because the curb proof roll was good and it has not rain since

Comments: