

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20215386
Address: 2200 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Camera Test	Eric Sharp	Partial	Tuesday, July 05, 2022

Informational:

1 Misc

Met with Ops Techs from WU about gap in pipe connection and mandrel string in a couple of the manholes/inverts. 6/29/22 ES

Spoke with Reese again about getting measurements on drop lines inside MH A-3 and A-4 as well as cleaning mandrel string from MH A-3 and A-5. Rudy was to be working on those this afternoon. 7/5/22 ES

Comments: