



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20100272, Building Permit - Commercial
Address: 346 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Failed	Wednesday, March 02, 2011

Corrective Action Required

1 MISC

HANDICAPPED-ACCESSIBLE SIGN REQUIRED AT NORTH RESTROOM

Corrective Action Required

2 MISC

ELECTRICAL RECEPTACLE @ S.E. CORNER NOT HOT FOR TEST. IF NOT WIRED, BLANK-OFF.

Corrective Action Required

3 MISC

HVAC WORK UNDER SEPARATE PERMIT NOT YET REQUESTED FOR FINAL INSPECTION -- REQUIRED TO BE APPROVED BEFORE CERTIFICATE OF OCCUPANCY IS ISSUED.

Occupancy Inspection - Fire	Joe Dir	Temporary C of O	Wednesday, March 02, 2011
--	---------	------------------	---------------------------

Corrective Action Required

1

Comments: OK TO SET FOR BUSINESS. NO PUBLIC UNTIL APPROVED.