

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215295  
Address: 2110 SW RED BARN LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Wednesday, July 06, 2022

Corrective Action Required:

1 Misc

- address rafter to ceiling joist connection
- address rafter/ceiling joist to top plate connection to be to plans
- address s3.2 10 connections at deck
- complete bath vent fans install though out
- address RA panning at Rex room to unfinished area
- complete concrete room electrical

**Comments:**