

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214367
Address: 3110 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Wednesday, July 06, 2022

Corrective Action Required:

1	Misc	-complete pfh at all places per plans -anchor bolts to be in the middle 1/3 of sill plate -address front entry wall not tied to garage or master closet wall -fire block into furr down in pantry -fire block chase in pantry for dwv/pex into furr down -cspf at dining room slider -fire block dead space on basement bath -fireblock furr down in basement bath -anchor all steel columns
---	------	--

Comments: