## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 DEVSERVICES.CITYOFLS.NET

## **Inspection Summary**

Permit #:PRRES20215320Address:2118 SW RED BARN LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection	:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential		Shawn Hoffman	Failed	Thursday, July 07, 2022
Corrective	Action Required:			
1	Misc	<ul> <li>-remove covering at garage portal frame to inspect nailing to header</li> <li>-address ceiling joists and hip rafter in master bed over notched</li> <li>-roof supports not to land on 2x12's in master bath per plans</li> <li>-complete bath fans vent to exterior throughout</li> <li>-address lvl above bed 2 over notched at bearing ends</li> <li>-solid block under cantilever in basement</li> <li>-address deck post to beam connection</li> </ul>		

Comments: