

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214577
Address: 3116 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Thursday, July 07, 2022

Corrective Action Required:

1	Misc	-vertical to horizontal fire blocking every 10' (missing and penetrations) -SEAL GAP AT "STORAGE BEHIND BAR, STILL MISSING AT REC ROOM AND BED 4 -anchor bolts to be in the middle 1/3 of sill plate in basement-TIGHTEN NUTS -top plate penetration in bath 3-SEE PEX LINE AT TOILET AND HOT WATER PEX AT VANITY -fire block furr out wall to ceiling space in bed 4-SEAL PENETRATION AT NM BY ENTRY DOOR -COMPLETE BATH EXHAUST IN BED 4 -truss hangers to plans incorrect hanger sul26-SEE HIP TRUSS CJ2
---	------	---

Comments: