

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216532
Address: 1812 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Thursday, July 07, 2022

Corrective Action Required:

2	Misc	Fire block floor at hvac chase garage wall Complete plumbing garage at master bathroom Provide joist hanger at 4x LVL garage entry Repair floor bathroom 4 Provide joist hanger at 4x LVL stairs living room Missing nails in hangers living room at stairs Nail off hanger's dining room joist Strap top plate master closet Fire block penetration bathroom 2 Vertical fire block stairs wall in basement
---	------	--

Comments: