

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214341
Address: 3125 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Thursday, July 07, 2022

Corrective Action Required:

1	Misc	-fire block fridge wall furr out to ceiling space -address pex drilled closer than 2" above pantry/powder room , kitchen/great room multiple places -fire block hvac chase 2nd floor
---	------	--

Comments: