

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20213681  
Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Robb Popp	Failed	Thursday, July 07, 2022

Informational:

1	Misc	-3rd party inspector to verify and document nailing pattern at exterior sheathing  -REPAIR RATED CEILING IN CORRIDOR OUTSIDE OF 338 -REPAIR RATED CEILING IN UNITS 338, 340, 341, 342-CUT ROCK FROM MEMBER TO MEMBER AND REPLACE  -SUPPORT RC CHANNEL AT 2ND FLOOR CORRIDOR WALLS AT EACH END, PROTECT ALL DWV AND DRYER DUCT WITHIN 1.25" OF FACE OF RC CHANNEL-ALL LOCATIONS
---	------	---

Corrective Action Required:

2	THIRD FLOOR	AREA "A" -RC CHANNEL AT UNITS AND CORRIDORS -1ST LAYER AT BATHROOM WALLS -SCREW PATTERN AT UNITS AND CORRIDORS EXCEPT AS NOTED IN CORRECTIONS
---	-------------	--

Corrective Action Required:

3	SECOND FLOOR	AREA "A" -RC CHANNEL AT UNITS AND CORRIDOR CEILINGS ONLY -FIRST LAYER AT BATHROOMS
---	--------------	--

Corrective Action Required:

4	FIRST FLOOR	
---	-------------	--

Corrective Action Required:

5            STAIR TOWER 1       STAIR TOWER "A"

-RC CHANNEL AT CEILING AND THIRD FLOOR LANDING

**Comments:**