

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20211976
Address: 811 NE LAKEWOOD BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mark Harding	Failed	Friday, July 08, 2022

Corrective Action Required:

1	Misc	<p>this inspection should of been updated 4/12 along with fire dept. again on 5/5 when i met with Phil Livota. anothoer site visit 7/6 .</p> <p>The existing door shall be removed and a 2hr wall installed as per plans. The east walk through door on the existing space shall be removed and a 90 minute rated door installed. the emergency lights on the outside of the patio are not connected to the emergency exit sign/light on the inside of the door for the patio.</p> <p>all these items were brought forwth the day all the staff from both sides met on site.</p>
---	------	--

Comments: