

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216204
Address: 1932 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Friday, July 08, 2022

Corrective Action Required:

1	Misc	-install all doors and windows -provide attic access for kitchen and front bedroom attic space -provide security blocking basement door -provide (2) 1/2" through bolts each post/beam connection at deck Ok to insulate
---	------	--

Comments: