

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213908
Address: 2317 SW CHASE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Friday, July 08, 2022

Corrective Action Required:

1	Miscellaneous Correction	Anchor bolts to be in middle third of plate garage west side Security blocking at deck doors Strap DWV 2" and under vertical through out Fire block nm penetration master shower Missing hanger dressing room rafter Provide ladder for inspection of covered deck, or uncover Address over notched studs basement near electrical panel Provide 1" clearance at B vent in attic space
---	--------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: