

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213908  
Address: 2317 SW CHASE CIR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                 | Inspector:    | Outcome: | Date:                 |
|---|---------------|----------|-----------------------|
| <b>Gas Service Inspection - Residential</b> | Shawn Hoffman | Failed   | Friday, July 08, 2022 |

Corrective Action Required:

|   |                          |  |
|---|--------------------------|--|
| 1 | Miscellaneous Correction | Minimum of 10 psi for inspection, only 7 psi at time of inspection |
|---|--------------------------|--|

**Comments:**