

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20216411  
Address: 710 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection</b> <b>- Commercial</b>	Robb Popp	Partial	Friday, July 08, 2022

Corrective Action Required:

1	THE FOLLOWING AREAS ARE APPROVED	DWV AT 114,103,107,109, 100
---	--	-----------------------------

Corrective Action Required:

2	Miscellaneous Correction	-PROVIDE CLEAN OUT AT EAST EXTERIOR CHANGE OF DIRECTION
---	-----------------------------	---

**Comments:**