

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20215028  
Address: 2601 NE MCBAINE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Fire Hydrant</b>	Adam Nacke	Failed	Monday, July 11, 2022

Corrective Action Required:  
1      Miscellaneous      7-11-22 RH. Fire Hydrant needs to be turned so it is facing the road.  
    Correction

**Comments:**