




July 11, 2022

Summit Homes  
120 SE 30<sup>th</sup> St.  
Lee's Summit, MO 64082

**RE: Revision of blocking between floor joists under kitchen island for Lot #1 Cobey Creek –504 SE David Rd.  
Lee's Summit, MO 64082 – Permit # PRRES20215762**



**Recommended modifications:**

- Floor joists shall be Douglas Fir Larch #2 2x10 doubled as shown in image above.
- Install 2x4 blocking at 48" oc under kitchen island.

Sincerely,

Bradley Huxol, PE

