

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214577
Address: 3116 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Monday, July 11, 2022

Corrective Action Required:

1	Misc	-seal dwv penetration into furr down in basement bath -fire block furr out wall to ceiling space in bed 4-SEAL PENETRATION AT NM BY entryway -truss hangers to plans incorrect hanger sul26-SEE HIP TRUSS CJ2
---	------	---

Comments: