

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20220450  
Address: 4704 NE POCONO CIR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Monday, July 11, 2022

Corrective Action Required:

1	Misc	-Seal the return air at master closet wall from roof **I can see gap around the duct attachment to the sheathing and gap between the sheathing and 2x6. Seal these gaps so that air is not drawn from the attic
---	------	---

\*\*OK TO INSULATE

Comments: