

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216043
Address: 1617 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Monday, July 11, 2022

Corrective Action Required:

1	Misc	-header to top plate connection per design at garage portal frame-PROVIDE 2 ROWS 16d SINKERS 3" OC -rear dining room windows framed to cspf per plans and design-CSPF REQUIRES MIN (3") 11 1/4" HEADER AND EXTERIOR NAILING PATTERN- SEE G4 DETAILS -address notched triple lvl at hanger see great room / foyer (provide engineering for fix)-NO ENGINEERED CORRECTION ON FILE -address holes border too close to each other above master bath- PROVIDE HANGER AT DOUBLED JOISTS -seal penetrations in joist space above bed 2 entry for RA-NOT DONE
---	------	---

Comments: