CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213848
Address: 3212 SW MARY ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Passed	Monday, July 11, 2022

Corrective Action Required:

1	Misc	•No footing inspection on file (FYI) •Secure csst gas line at fire place •Strap top plate less than 24” over lap, dining room right side of sliding door •Strap top plate right side of fire place •Nail exterior corner right of fire place, top 1/3 •Straps at structural post at entry and stairs need 6” overlap and no less than 4 nails each side •Open porch covering for inspection •Solid Block cantilever in basement •Anchor steel columns basement •Provide hangers at header joist basement near electrical panel

Comments: