

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215028
Address: 2601 NE MCBAINE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Fire Hydrant	Adam Nacke	Passed	Monday, July 11, 2022

Corrective Action Required:

1	Miscellaneous Correction	7-11-22 RH. Fire Hydrant needs to be turned so it is facing the road. 7-11-22 RH. Fire Hydrant was rotated correctly.
---	-----------------------------	--

Comments: