

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214472
Address: 2946 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Monday, July 11, 2022

Corrective Action Required:

2	Misc	Final grading and sod Install irrigation system Splash blocks Provide 2@1/2" through bolts on deck post to beam connections Seal top of meter can and A/C disconnect Sump discharge minimum of 36" away from foundation
---	------	--

Comments: