

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20204940  
Address: 322 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Robb Popp	Failed	Monday, July 11, 2022

Corrective Action Required:

1	Misc	-3" Bath fan vents not allowed-3" FLEX DUCT IS NOT ALLOWED IN ANY LENGTH-PLEASE SEE 2018 IRC CODE SECTION TABLE M1504.2-REMOVE ALL 3" FLEX DUCTING AND SUPPORT PER CODE
---	------	---

**Comments:**