

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216421
Address: 3124 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, July 12, 2022

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | -maintain gravel filter on drive, min 6" lift required
-furr out and down for dwv in garage, (2x6's NEEDED ON CEILING FUR DOWNS FOR R-19 INSULATION)
-address lib in kitchen cut, (2 NAILS EACH STUD/PLATE STRAPS)
-missing multiple truss hangers throughout (NOT DONE)
-All truss lateral bracing per plans
-address hole drilled closer than 2" to top of lvl for NM see basement stairs (NOT ADDRESSED)

-Provide jumper from ground bar to neutral bar or land CEE on neutral bar |
|---|------|---|

Comments: