

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215655
Address: 1621 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Tuesday, July 12, 2022

Corrective Action Required:

1	Misc	nail 2x4 to header per plans on portal frame Address rafters landing on blocks through out Provide anchor bolt on plate 12" from end and back at least 7 x the thickness of bolt at single garage door Add anchor bolts to plate at double garage bay per code Repair top plate and strap in laundry/ entry wall Anchor steel columns in basement Complete RA panning above basement bathroom Fire block soffit in closet of bedroom 3 Security blocking doors in basement Fire block soffit around I beam in bedroom 4
---	------	--

Comments: