

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215781
Address: 4732 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Adam Nacke	Failed	Tuesday, July 12, 2022

Informational:

1 Misc

7-7-22 RH. Forms are in place and aggregate is present and compacted. No Sidewalk

7-12-22 RH. Driveway meets ADA and LS specification. Need to patch curb in front of driveway.

Comments: