

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213431
Address: 420 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Shawn Hoffman	Partial	Tuesday, July 12, 2022

Corrective Action Required:

1	Address the building and all spaces, both front and back doors. Emergency egress lighting was not operational and failed. Add emergency egress lighting at the top of each stairwell leading from the two upstairs occupancies.
---	---

Informational:

2	Misc	No erosion control issues. 7/12/22 ES
---	------	---------------------------------------

Comments: