

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20214368  
Address: 3106 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Tuesday, July 12, 2022

Corrective Action Required:

1 Misc

Complete exhaust vent first floor bathroom  
Attach csst gas line at fire place  
Unable to inspect cspf nail pattern on second floor bedroom near entry  
Nail 3 stud pack together north west bedroom  
Fire block top plate penetration hallway at front bedroom  
Fire block penetration top plate laundry  
Complete ductwork all bathroom fans  
Fire block top plate penetrations at master bedroom  
Project wiring within 6' if attic access  
Open section of patio roof for inspection

**Comments:**