



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20100272, Building Permit - Commercial
Address: 346 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Friday, March 04, 2011

Corrective Action Required

4 MISC

SOME ELECTRICAL CIRCUITS YET TO BE LABELED AT VARIOUS PANELS.

Corrective Action Required

5 MISC

SUPPORT WATER SERVICE ENTRY PIPING NEAR BACKFLOW PREVENTION DEVICE.

Comments: OK TO SET UP FOR BUSINESS.