

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214074
Address: 420 NW KAYLEA CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Eric Sharp	Passed	Tuesday, July 12, 2022

Corrective Action Required:

1	Misc	Sidewalk has not been poured. Plot plan shows sidewalk extends from East property line to ADA ramp. This needs to be poured. 7/7/22 ES
---	------	--

Informational:

2	Misc	Sidewalk panel and replacement ADA turning space were formed up with aggregate in and compacted. 7/11/22 ES
---	------	---

Sidewalk and ADA TS both meet LS and ADA specs. 7/12/22 ES

Comments: