

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215487
Address: 2002 SW 26TH TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Mitchell Schwarz	Partial	Tuesday, July 12, 2022

Informational:

1	THE FOLLOWING AREAS ARE APPROVED	-2" conduit for communication lines from 26th st curb line to building
---	--	--

Corrective Action Required:

2	Misc	conduit for light pole bases to be trenced 18" deep, 24" deep if under parking lot.
---	------	---

Corrective Action Required:

3	Misc	Inspection under ground conduit for light poles nort and south side okay to cover. East side to be dug deeper
---	------	---

Comments: