## LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1303
TDD (816) 969-7407

## PLANS REVIEW CONDITIONS

Permit No: PRCOM20110060 Date: Mar

Project Title: Massage Heights

Location: 970 NW BLUE PKWY, Unit:D

LEES SUMMIT, MO 64086

Type of Work: Sprinkler

Occupancy Group: B

Description: Massage parlor tenant finish
Construction Type: Type IIB (Unprotected)

Map Page: 195A

Date: March 04, 2011

Applicant:

Alliance Fire Protection 130 W. 9th Ave, Suite 101 North Kansas City, MO 64116

(913) 888-0647

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review Reviewed By: Jim Eden Released for Construction

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Plans received March 1, 2011.

2. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule a flow and alarm test.

3. Verify sprinkler heads are the proper distance off the wall in first two rooms off of the lobby.

Verified at inspection.