



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20100272, Building Permit - Commercial  
Address: 346 SW BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Partial	Friday, March 04, 2011

Corrective Action Required  
4 MISC

SOME ELECTRICAL CIRCUITS YET TO BE LABELED AT VARIOUS PANELS.

Corrective Action Required  
5 MISC

SUPPORT WATER SERVICE ENTRY PIPING NEAR BACKFLOW PREVENTION DEVICE.

**Comments: OK TO SET UP FOR BUSINESS.**