

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215320  
Address: 2118 SW RED BARN LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Not Ready	Wednesday, July 13, 2022

Corrective Action Required:

1 Misc

- address ceiling joists and hip rafter in master bed over notched(items covered)
- roof supports not to land on 2x12's in master bath per plans
- complete bath fans vent to exterior throughout
- address lvl above bed 2 over notched at bearing ends(covered)
- solid block under cantilever in basement (covered)
- address deck post to beam connection

**Comments:**