



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRRES20110168, Building Permit - Residential
Address: 3408 SW LOIS LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	David Landes	Partial	Monday, March 07, 2011

Partial Correction

1	E4104 POOL BONDING	- POOL LIGHTS BONDED. - CALL FOR REINSPECTION FOR BONDING OF POOL APRON.
---	--------------------	---

Comments: