CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20213954

Address: 2017 SW OSAGE DR, LEES SUMMIT, MO 640822015 SW OSAGE DR, LEES

SUMMIT, MO 64082

Inspected On: Wednesday, July 13, 2022

Inspected By: Patrick Schonfeldt

Expiration Date: 8/12/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Residential

Patrick Schonfeldt Temporary C of O Wednesday, July

13, 2022

Corrective Action Required:

1 Misc -final grade and sod

-splash blocks all downspout and sump pump discharge locations,

min 36" discharge from foundation

-provide permanent address at electric meter cans and disconnects

-provide gravel base at water meter pit

UNIT 2015 OK

NO INSPECTION PERFORMED ON UNIT 2017