

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201210
Address: 2924 NW THOREAU DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Adam Nacke	Passed	Wednesday, July 13, 2022

Informational:

1	Misc	Driveway is framed up and has aggregate in place and compacted. 11/29 ES
---	------	--

Corrective Action Required:

2	Misc	Finished driveway along Thoreau meets LS and ADA specs. Driveway along Carson can currently only be 10 feet wide. Contractor is thinking about removing wings on the Thoreau driveway. If removed, the Carson driveway could be 15 feet wide. Forms were placed and aggregate was present and compacted. RP 12-3-21
---	------	---

Corrective Action Required:

3	Misc	Wings were removed from the Thoreau driveway and the Carson driveway is 15 feet wide which meets LS spec. Someone walked through the driveway, 3 footprints were visible around the trash piled up. Need to remove and replace the approach. RP 12-10-21
---	------	--

Informational:

4	Misc	7-13-22 AN approach was replaced and looks good
---	------	---

Comments: